



**TOWNSHIP OF NORTH HURON**  
**WATER AND WASTE WATER MONTHLY REPORT**

**July 2017**

Prepared by: Veolia Water

**INTRODUCTION**

**1) NORTH HURON WATER SYSTEMS**

**a) WINGHAM WATER**

- i) **Laboratory Results:** All lab results were compliant
- ii) **Operational Parameters:** Data being stored on the online Hach WIMS database and the Township of North Huron Network, information is available upon request
- iii) **Regulatory:** There were no regulatory issues during this reporting period
- iv) **Distribution:** All Weekly and monthly routine maintenance was performed
- v) **Maintenance and services Performed:** replaced curb stop, camera-d new service, water meter new install, raised a service box, Water Turn off and Turn on for plumbers to replace main valve and we could replace service box

**b) BLYTH WATER**

- i) **Laboratory Results:** All lab results were compliant
- ii) **Operational Parameters:** Data being stored on the online Hach WIMS database and the Township of North Huron Network, information is available upon request
- iii) **Regulatory:** There were no regulatory issues during this reporting period
- iv) **Distribution:** All Weekly and monthly routine maintenance was performed
- v) **Maintenance and services Performed:** repaired water leak

**c) DWQMS (Drinking Water Quality Management System)**

2017 Management Review was held on July 19 2017, Meeting minutes and action outcomes sent via e-mail on July 20, 2017

New CAO/ Public Works Director is to review the operational plan; a CAO has been hired for North Huron for the start of Sept, once the new CAO has had time to review the operational plan Veolia will ensure the plan is endorsed by Top management.

QMS Rep working to close off non-conformance found in the Internal Audit

**2) FACILITIES**

**Airport:** All samples during the reporting period were compliant



### 3) NORTH HURON WASTEWATER SYSTEMS

#### a) WINGHAM WASTEWATER

- i) **Laboratory Results:** All lab results were compliant
- ii) **Operational Parameters:** Data being stored on the online Hach WIMS database and the Township of North Huron Network, information is available upon request
- iii) **Regulatory:** There were no regulatory issues during this reporting period
- iv) **Distribution:** All Weekly and monthly routine maintenance was performed
- v) **Maintenance and services Performed:** Sewer backup & Sewer camera (home owner wants to start the process to replace service Charles st), NH daycare unplugged sewer lateral, Attempted to camera a sewer backup but had no access point homeowner to contact a plumber and to call us to come back and camera the backed up sewer in August

#### b) BLYTH WASTEWATER

- i) **Laboratory Results:** All lab results were compliant
- ii) **Operational Parameters:** Data being stored on the online Hach WIMS database and the Township of North Huron Network, information is available upon request
- iii) **Regulatory:** There were no regulatory issues during this reporting period
- iv) **Distribution:** All Weekly and monthly routine maintenance was performed
- v) **Maintenance and services Performed:** Installed new 8" gate valve, 1-8" gasket and bolt package and repaired first aeration valve clarifier

### 4) VEOLIA AND NORTH HURON OPERATIONS MEETINGS

- a) N/A

### 5) ITEMS OUTSTANDING

N/A

