



TOWNSHIP OF NORTH HURON
WATER AND WASTE WATER MONTHLY REPORT

August 2017

Prepared by: Veolia Water

INTRODUCTION

1) NORTH HURON WATER SYSTEMS

a) WINGHAM WATER

- i) **Laboratory Results:** All lab results were compliant
- ii) **Operational Parameters:** Data being stored on the online Hach WIMS database and the Township of North Huron Network, information is available upon request
- iii) **Regulatory:** There were no regulatory issues during this reporting period
- iv) **Distribution:** All Weekly and monthly routine maintenance was performed
- v) **Maintenance and services Performed:** changed a water meter, installed a service box extension for new cement in a driveway, changed out a curb stop and water meter
- vi) **Customer complaints:** 1 complaint of mud and sand in water- Operator Flushed the service line, had a lot of rust come out, property is on a dead end with no blowoff or hydrant to flush regularly. 1 complaint of rusty water for the past 3 months, Operator removed meter and flushed the service from the street, found that a valve was still shut from a construction project causing a dead end for this service, once the valve was opened and line flushed water was clear and homeowners were satisfied, ICS annual calibrations of Flowmeters and analyzers

b) BLYTH WATER

- i) **Laboratory Results:** one adverse sample TC:1 at 182 Thuell st, Resamples collected and came back clear and compliant
- ii) **Operational Parameters:** Data being stored on the online Hach WIMS database and the Township of North Huron Network, information is available upon request
- iii) **Regulatory:** There were no regulatory issues during this reporting period
- iv) **Distribution:** All Weekly and monthly routine maintenance was performed
- vii) **Maintenance and services Performed:** ICS annual calibrations of Flowmeters and analyzers

c) DWQMS (Drinking Water Quality Management System)

External DWQMS Documentation Audit scheduled for October 2017

2) FACILITIES

- a. Acu-Tech Inspected all fall arrest equipment

a) Airport: all results were compliant during the reporting period



3) NORTH HURON WASTEWATER SYSTEMS

a) WINGHAM WASTEWATER

- i) **Laboratory Results:** All lab results were compliant
- ii) **Operational Parameters:** Data being stored on the online Hach WIMS database and the Township of North Huron Network, information is available upon request
- iii) **Regulatory:** There were no regulatory issues during this reporting period
- iv) **Distribution:** All Weekly and monthly routine maintenance was performed
- viii) **Maintenance and services Performed:** ICS annual calibrations of Flowmeters and analyzers, Camera-d 2 sewers for customers

b) BLYTH WASTEWATER

- i) **Laboratory Results:** All lab results were compliant
- ii) **Operational Parameters:** Data being stored on the online Hach WIMS database and the Township of North Huron Network, information is available upon request
- iii) **Regulatory:** There were no regulatory issues during this reporting period
- iv) **Distribution:** All Weekly and monthly routine maintenance was performed
- ix) **Maintenance and services Performed:**
ICS annual calibrations of Flowmeters and analyzers

4) VEOLIA AND NORTH HURON OPERATIONS MEETINGS

- a) N/A

5) ITEMS OUTSTANDING

N/A

