



TOWNSHIP OF NORTH HURON
WATER AND WASTE WATER MONTHLY REPORT

Sept 2017

Prepared by: Veolia Water

INTRODUCTION

1) NORTH HURON WATER SYSTEMS

a) WINGHAM WATER

- i) **Laboratory Results:** All lab results were compliant
- ii) **Operational Parameters:** Data being stored on the online Hach WIMS database and the Township of North Huron Network, information is available upon request
- iii) **Regulatory:** There were no regulatory issues during this reporting period
- iv) **Distribution:** All Weekly and monthly routine maintenance was performed
- v) **Maintenance and services Performed:** Replaced bent curb stop, Replaced 2 water meters
- vi) **Customer complaints:** No complaints

b) BLYTH WATER

- i) **Laboratory Results:** All lab results were compliant
- ii) **Operational Parameters:** Data being stored on the online Hach WIMS database and the Township of North Huron Network, information is available upon request
- iii) **Regulatory:** There were no regulatory issues during this reporting period
- iv) **Distribution:** All Weekly and monthly routine maintenance was performed, Hydrant Flushing was scheduled for September however with the Township requesting Veolia's assistance on the Westmoreland st project and Assistance with CT Environmental Hydrant Flushing has been postponed until November
- v) **Maintenance and services Performed:** Water and Sewer service hookup, new water meter, assisted/oversaw work being completed with road re-construction project on Westmoreland, numerous sample collected for Westmoreland
- vi) **Customer complaints:** No complaints

c) DWQMS (Drinking Water Quality Management System)

External NSF Full Scope Audit scheduled for October 12th 2017- All information will be forwarded to The Township once completed.

2) FACILITIES

a) Airport:

- i. All samples compliant during the reporting period
- ii. UV system not performing within the guidelines, a PBWN has been issued and will be lifted once the UV is working Properly water quality has remained stable



3) NORTH HURON WASTEWATER SYSTEMS

a) WINGHAM WASTEWATER

- i) **Laboratory Results:** All lab results were compliant
- ii) **Operational Parameters:** Data being stored on the online Hach WIMS database and the Township of North Huron Network, information is available upon request
- iii) **Regulatory:** There were no regulatory issues during this reporting period
- iv) **Distribution:** All Weekly and monthly routine maintenance was performed
- v) **Maintenance and services Performed:** Assisted CT Environmental with flushing and camera work, provided a camera of Sewer service
- vi) **Customer complaints:** No complaints

b) BLYTH WASTEWATER

- i) **Laboratory Results:** All lab results were compliant
- ii) **Operational Parameters:** Data being stored on the online Hach WIMS database and the Township of North Huron Network, information is available upon request
- iii) **Regulatory:** There were no regulatory issues during this reporting period
- iv) **Distribution:** All Weekly and monthly routine maintenance was performed
- v) **Maintenance and services Performed:** Yard lights replaced at Sewage plant
- vi) **Customer complaints:** No complaints

4) VEOLIA AND NORTH HURON OPERATIONS MEETINGS

- a) Would like to schedule a meeting with New Public works Director to review DWQMS and ensure our Operational plan is endorsed by Top Management- would like to aim for meeting in November

5) ITEMS OUTSTANDING

N/A

