



**TOWNSHIP OF NORTH HURON**  
**WATER AND WASTE WATER MONTHLY REPORT**  
**December 2017**

Prepared by: Veolia Water

**INTRODUCTION**

**1) NORTH HURON WATER SYSTEMS**

**a) WINGHAM WATER**

- i) **Laboratory Results:** All lab results were compliant
- ii) **Operational Parameters:** Data being stored on the online Hach WIMS database and the Township of North Huron Network, information is available upon request
- iii) **Regulatory:** There were no regulatory issues during this reporting period
- iv) **Distribution:** All weekly and routine maintenance was performed
- v) **Maintenance and services Performed:** 2 watermain breaks repaired (Angus St & Water St), installed new water meter, installed pre and post chlorine analyzers at well 4(form 2 on file)
- vi) **Customer complaints:** 1 complaint November 30<sup>th</sup> (did not report in November Summary report) Rusty water complaint- Operators flushed main water line until clear

**b) BLYTH WATER**

- i) **Laboratory Results:** All lab results were compliant
- ii) **Operational Parameters:** Data being stored on the online Hach WIMS database and the Township of North Huron Network, information is available upon request
- iii) **Regulatory:** There were no regulatory issues during this reporting period
- iv) **Distribution:** All weekly and routine maintenance was performed
- v) **Maintenance and services Performed:** water shut off for customer
- vi) **Customer complaints:** No complaints to report during reporting period

**c) DWQMS (Drinking Water Quality Management System)**

On the Job training with Operators Annual Risk Assessment review, Emergency evacuation procedure reviewed, operational plan annual review

**2) FACILITIES**

**a) Airport:**

- i. **Laboratory Results:** All lab results were compliant
- j. **Maintenance and services performed:** UV lights and filters replaced



### 3) NORTH HURON WASTEWATER SYSTEMS

#### a) WINGHAM WASTEWATER

- i) **Laboratory Results:** All lab results were compliant
- ii) **Operational Parameters:** Data being stored on the online Hach WIMS database and the Township of North Huron Network, information is available upon request
- iii) **Regulatory:** There were no regulatory issues during this reporting period
- iv) **Distribution:** All weekly and routine maintenance was performed
- v) **Maintenance and services Performed:** Plugged sewer (camera and removed plug), Repaired a broken clean out cap
- vi) **Customer complaints:** No complaints during reporting period

#### b) BLYTH WASTEWATER

- i) **Laboratory Results:** All lab results were compliant
- ii) **Operational Parameters:** Data being stored on the online Hach WIMS database and the Township of North Huron Network, information is available upon request
- iii) **Regulatory:** There were no regulatory issues during this reporting period
- iv) **Distribution:** All weekly and routine maintenance was performed
- v) **Maintenance and services Performed:** camera sewer due to flooded basement, Maitland welding finished repair work on clarifier sludge scrapper, repaired scum box heater
- vi) **Customer complaints:** No complaints during reporting period

### 4) VEOLIA AND NORTH HURON OPERATIONS MEETINGS

- a) N/A

### 5) ITEMS OUTSTANDING

2 Return RAS pumps ordered for Blyth Sewage to be installed when they come in  
#2 Blower is down at Blyth Sewage- Quote was submitted to Public works director- awaiting approval

