



TOWNSHIP OF NORTH HURON
WATER AND WASTE WATER MONTHLY REPORT

January 2018

Prepared by: Veolia Water

INTRODUCTION

1) NORTH HURON WATER SYSTEMS

a) WINGHAM WATER

- i) **Laboratory Results: Laboratory Results:** All lab results were compliant, 60 Month treated water Sodium and Fluoride were sampled and the results were below the Maximum acceptable concentration for both wells.
- ii) **Operational Parameters:** Data being stored on the online Hach WIMS database and the Township of North Huron Network, information is available upon request
- iii) **Regulatory:** There were no regulatory issues during this reporting period
- iv) **Distribution:** All weekly and routine maintenance was performed, Meter reading
- v) **Maintenance and services Performed:** Water-main break repaired
- vi) **Customer complaints:** Customer wondering about water shut off valve- operator showed where the curb stop was for the property and advised on procedures for how to get any issues addressed

b) BLYTH WATER

- i) **Laboratory Results: Laboratory Results:** All routine samples were compliant during the reporting period, 60 Month Treated Water Sodium and Fluoride results came back over the Maximum Acceptable Concentrations, 2 AWQI's were assigned, resample results also came back over the MAC and as a results the Huron County Health Unit Supplied the Township of North Huron with an information letter to be distributed to all Blyth Water consumers.
- ii) **Operational Parameters:** Data being stored on the online Hach WIMS database and the Township of North Huron Network, information is available upon request
- iii) **Regulatory:** There were no regulatory issues during this reporting period
- iv) **Distribution:** All weekly and routine maintenance was performed
- v) **Maintenance and services Performed:** Repaired 1 Water-main break
- vi) **Customer complaints:** No complaints during the reporting period

c) DWQMS (Drinking Water Quality Management System)

Township of North Huron Reeve, CAO & Public Works director were directed at the monthly meeting to read the operational plan that is posted on the North Huron Website and they have been supplied the commitment and Endorsement form to sign and return to Veolia staff to sign.



2) FACILITIES

- a) Airport: All samples during this reporting period were compliant

3) NORTH HURON WASTEWATER SYSTEMS

a) WINGHAM WASTEWATER

- i) **Laboratory Results: Laboratory Results:** All lab results were compliant
- ii) **Operational Parameters:** Data being stored on the online Hach WIMS database and the Township of North Huron Network, information is available upon request
- iii) **Regulatory:** There were no regulatory issues during this reporting period
- iv) **Distribution:** All weekly and routine maintenance was performed
- v) **Maintenance and services Performed:** 4 Sewers camera'd, Power flushed the same sewer main twice
- vi) **Customer complaints:** No complaints during the reporting period
- vii)

b) BLYTH WASTEWATER

- i) **Laboratory Results: Laboratory Results:** All lab results were compliant
- ii) **Operational Parameters:** Data being stored on the online Hach WIMS database and the Township of North Huron Network, information is available upon request
- iii) **Regulatory:** There were no regulatory issues during this reporting period
- iv) **Distribution:** All weekly and routine maintenance was performed
- v) **Maintenance and services Performed:** 2 Secondary bypasses
- vi) **Customer complaints:** No complaints during the reporting period
- vii)

4) VEOLIA AND NORTH HURON OPERATIONS MEETINGS

- a) Monthly Meeting February 8, 2018, 9:00am at the Veolia Wingham office (435 Minnie St)

5) ITEMS OUTSTANDING

Veolia Staff working on Annual Reports/Summaries to be submitted to MOECC and Owner

