

# **NORTH HURON WATER & WASTEWATER MASTER PLAN**

**RESERVE CAPACITY UPDATE  
PRESENTATION TO COUNCIL**

**JULY 5, 2019**



# Agenda

- Master Plan Scope
- Servicing Commitments
- Water System Reserve
  - Wingham
  - Blyth
- Wastewater System Reserve
  - Wingham
  - Blyth
- Summary
- Questions

# Master Plan Scope

- Review potential scale and rate of development
- Determine triggers for major facility (e.g. treatment, storage, pumping) expansion
- Analyze water distribution & wastewater collection capacities relative to projected needs
- Physical inspections – CCTV sewers, electrical/mechanical of treatment/pumping facilities
- Asset management planning
- Rate reviews & Financial Plan updates

# Servicing Commitments

- Existing customers
- Development plans, draft plans, pending...
  - Wingham
    - A2A Lands - 454 units
    - Hutton Heights - 100 units
  - Blyth
    - GJAJ Holdings - 105 units
    - Each community infill - 25 units
- Cross-Border Servicing w/ Morris-Turnberry

# Servicing Commitments

- For residential development, determine water demand and wastewater flow per Equivalent Residential Unit (ERU):
  - Wingham
    - Water - 1.23 m<sup>3</sup>/d/ERU
    - Wastewater - 1.25 m<sup>3</sup>/d/ERU
  - Blyth
    - Water - 1.62 m<sup>3</sup>/d/ERU
    - Wastewater - 0.84 m<sup>3</sup>/d/ERU
- Apply above to development unit values

# Servicing Commitments

- Cross-Border Servicing Agreement (CBSA) with M-T, totals for all properties:
  - Water - 682.5 m<sup>3</sup>/d
  - Wastewater - 247.7 m<sup>3</sup>/d
- Other commitments for Wingham:
  - Water - 712.2 m<sup>3</sup>/d
  - Wastewater - 723.8 m<sup>3</sup>/d
- Commitments for Blyth:
  - Water - 211 m<sup>3</sup>/d
  - Wastewater - 107 m<sup>3</sup>/d

# Water System Reserve


- Wingham
  - Well No. 3 Capacity - 6,537 m<sup>3</sup>/d
  - Well No. 4 Capacity - 5,270 m<sup>3</sup>/d
- Firm capacity = capacity with largest well out of service = 5,270 m<sup>3</sup>/d
- Current maximum day - 2,277 m<sup>3</sup>/d

# Water Treatment Capacity - Wingham

Uncommitted  
Reserve =  
1,598 m<sup>3</sup>/Day,  
30%

An additional  
1,299 ERUs

Existing  
Maximum  
Demand = 2,277  
m<sup>3</sup>/Day, 43%



Firm Capacity = 5,270  
m<sup>3</sup>/Day

Commitments =  
1,395 m<sup>3</sup>/Day,  
27%



# Water System Reserve

- Wingham Water Storage

Scenario	Volume Required (m <sup>3</sup> )			
	For Equalization	For Fire Protection	For Emergency	Total
Existing	569	785	339	1,693
Existing + Commitments	887	1,225	536	2,679

- Existing standpipe is 1,680 m<sup>3</sup>, but only about 232 m<sup>3</sup> is actually available.

# Water System Reserve


- Blyth
  - Well Nos. 1&2 Capacity - 1,149 m<sup>3</sup>/d
  - Well No. 5 Capacity - 1,728 m<sup>3</sup>/d
- Firm capacity = capacity with largest well out of service = 1,149 m<sup>3</sup>/d
- Current maximum day - 810 m<sup>3</sup>/d
  - Excludes some hydrant flushing days

# Water Treatment Capacity - Blyth

□ Uncommitted  
Reserve =  
128 m<sup>3</sup>/Day, 11%

Additional 79  
ERUs

■ Commitments =  
211 m<sup>3</sup>/Day, 18%



□ Existing  
Maximum  
Demand = 810  
m<sup>3</sup>/Day, 71%

Firm Capacity =  
1,149 m<sup>3</sup>/Day

# Water System Reserve

- Blyth Water Storage


Scenario	Volume Required (m <sup>3</sup> )			
	For Equalization	For Fire Protection	For Emergency	Total
Existing	203	454	164	821
Existing + Commitments	255	518	193	966

- Existing reservoir is 379 m<sup>3</sup>.

# Wastewater System Reserve

- Wingham
  - WWTP Capacity - 3,400 m<sup>3</sup>/d
    - Annual average day
  - Current average day - 2,314 m<sup>3</sup>/d
- Also need to look at quality, not just quantity. Analysis to date shows calculating reserve based on quantity is acceptable approach.

# Wastewater Treatment Plant Capacity - Wingham




Total Capacity =  
3,400 m³/Day

# Wastewater System Reserve

- Blyth
  - WWTP Capacity - 730 m<sup>3</sup>/d
    - Annual average day
    - Peak rating of 2,730 m<sup>3</sup>/d
  - Current average day - 406 m<sup>3</sup>/d
  - Also need to look at quality, not just quantity. Analysis to date shows calculating reserve based on quantity is acceptable approach.

# Wastewater Treatment Plant Capacity - Blyth



Total Capacity =  
730 m<sup>3</sup>/Day



# Summary - Wingham

Facility	Rated Capacity (m <sup>3</sup> /d)	Total Reserve (m <sup>3</sup> / d)	Uncommitted Reserve		
			(m <sup>3</sup> /d)	(% of Total)	(Approx. Units)
Water Treatment	5,270	2,993	1,598	30	1,299
WWTP	3,400	1,086	115	3	92

- Commitments assume full utilization of current CBSA values and full development of A2A and Hutton Heights.

# Summary - Blyth

Facility	Rated Capacity (m <sup>3</sup> /d)	Total Reserve (m <sup>3</sup> / d)	Uncommitted Reserve		
			(m <sup>3</sup> /d)	(% of Total)	(Approx. Units)
Water Treatment	1,149	339	119	10	79
WWTP	730	324	217	30	259

- Commitments assume full utilization of GJAJ Holdings.

*Thank you for your attention.*

Questions?