Month: December 2021								
Blyth Water Quality report								
PTTW Limts m3/day								
Well 1	654		**Well 2**	1123		**Well 5**	1728	
Well 1	**Flows (m3)**		**Well 2**	**Flows (m3)**		**Well 5**	**Flows (m3)**	
Min	70		**Min**	48		**Min**	83	
Max	212		**Max**	196		**Max**	209	
Average	129		**Average**	124		**Average**	139	
Total	3988		**Total**	3842		**Total**	4305	
Blyth Distribution Residuals								
Min	0.78							
Max	1.12							
Average	0.97							
Count	39							

Blyth Water samples				
Raw Water				
Date	**Location**	**TC**	**Ecoli**	
Dec 7-21	Well 1	0	0	
	Well 2	0	0	
	Well 5	0	0	
Dec 14-21	Well 1	0	0	
	Well 2	0	0	
	Well 5	0	0	
Dec 21-21	Well 1	0	0	
	Well 2	0	0	
	Well 5	0	0	
Dec 29-21	Well 1	0	0	
	Well 2	0	0	
	Well 5	0	0	
	Min	**0**	**0**	
	Max	**0**	**0**	
	Average	**0**	**0**	
	Adverse	**0**	**0**	
	Count	**12**	**12**	
Treated Water				
Date	**Location POE**	**TC**	**Ecoli**	**HPC**
Dec 7-21	Well 1 &2	0	0	<10
	Well 5	0	0	<10
Dec 14-21	Well 1 &2	0	0	<10
	Well 5	0	0	<10
Dec 21-21	Well 1 &2	0	0	<10
	Well 5	0	0	<10
Dec 29-21	Well 1 &2	0	0	<10
	Well 5	0	0	<10
	Min	**0**	**0**	**<10**
	Max	**0**	**0**	**<10**
	Average	**0**	**0**	**<10**
	Adverse	**0**	**0**	**0**
	Count	**8**	**8**	**8**
Distribution samples				
DAte	**Location**	**TC**	**Ecoli**	**HPC**
Dec 7-21	685 Queen St.	0	0	
	182 Thuell St.	0	0	10
	442 Mill St.	0	0	
Dec 14-21	Dinsley St. S.S.	0	0	
	182 Thuell St.	0	0	<10
	685 Queen St.	0	0	
Dec 21-21	298 Hamilton St.	0	0	
	182 Thuell St.	0	0	<10
	685 Queen St.	0	0	
Dec 29-21	256 Dinsley St.	0	0	
	182 Thuell St.	0	0	<10
	685 Queen St.	0	0	
	Min	**0**	**0**	**<10**
	Max	**0**	**0**	**10**
	Average	**0**	**0**	**<10**
	Adverse	**0**	**0**	**0**
	Count	**12**	**12**	**4**