

Month: December 2021

Wingham Water Quality report

PTTW Limits (m3)		Well 3	Flows (m3)	Well 4	Flows (m3)
	m3/day	Min		Min	
Well 3	6538	Max	413	Max	212
Well 4	5270	Average	852	Average	518
Total	11808	Total	588	Total	338
			18241		10471

Wingham Distribution residuals	
Min	0.7
Max	1.37
Average	1.04
Count	39

Wingham Water samples

Raw Water

Date	Location	TC	Ecoli
Dec 7-21	Well 3	0	0
	Well 4	0	0
Dec 14-21	Well 3	0	0
	Well 4	0	0
Dec 21-21	Well 3	0	0
	Well 4	0	0
Dec 29-21	Well 3	0	0
	Well 4	0	0
	Min	0	0
	Max	0	0
	Average	0	0
	Adverse	0	0
	Count	8	8

Treated Water

Date	Location	TC	Ecoli	HPC
Dec 7-21	Well 3	0	0	<10
	Well 4	0	0	<10
Dec 14-21	Well 3	0	0	<10
	Well 4	0	0	<10
Dec 21-21	Well 3	0	0	<10
	Well 4	0	0	<10
Dec 29-21	Well 3	0	0	<10
	Well 4	0	0	<10
	Min	0	0	<10
	Max	0	0	<10
	Average	0	0	<10
	Adverse	0	0	0
	Count	8	8	8

Distribution samples

Date	Location	TC	Ecoli	HPC
Dec 7-21	435 Minnie St.	0	0	<10
	120 Josephine St.	0	0	
	199 John St. E.	0	0	
Dec 14-21	55 Kerr Drive	0	0	<10
	120 Josephine St.	0	0	
	435 Minnie St.	0	0	
Dec 21-21	55 Kerr Dr.	0	0	<10
	120 Josephine St.	0	0	
	435 Minnie St.	0	0	
Dec 29-21	435 Minnie St.	0	0	<10
	120 Josephine St.	0	0	
	55 Kerr Dr.	0	0	
	Min	0	0	<10
	Max	0	0	<10
	Average	0	0	<10
	Adverse	0	0	0
	Count	12	12	4