

FDNH Report to North Huron Council for Activity for the Month of March 2016

Training:

Weekly Training:

- 1 week of his risk facility familiarization (41 personnel)
- 1 week of CPR/AED renewals – (35 personnel)
- 1 week of monthly equipment checks (33 personnel)

Full day training:

- ½ day Accident investigation – JHSC (1 person)
- ½ day Fire services traffic control (1 person)

Other:

Wingham Station Firefighter Kyle Vollmer is back from his leave of absence.

March Incidents:

8 March:

Alarm system activation
Morris-Turnberry
Outcome: No smoke. No fire. Faulty detector.
Notes: 2nd activation in 12 month period. Warning letter issued.

9 March:

Carbon Monoxide Alarm Activation
North Huron
Outcome: No CO present. Faulty alarm.

10 March:

Carbon Monoxide Alarm Activation
North Huron
Outcome: No CO present. Faulty alarm.

15 March:

Carbon Monoxide Alarm Activation
Morris-Turnberry
Outcome: No CO present. Faulty alarm.



21 March:

Motor Vehicle Collision

Morris-Turnberry

Outcome: 1 patient transferred by EMS.

22 March:

Medical first response

North Huron

Outcome: Call cancelled prior to FDNH response.

22 March:

Motor Vehicle Collision

Central Huron

Outcome: Patient's declined transfer by EMS.

Notes: 1 of the vehicles involved caught fire as a result of the collision. Fire extinguished by FDNH. Vehicle total loss.

24 March:

Power lines down/arcing

Morris-Turnberry

Outcome: Secured site until Hydro One arrived.

30 March:

Smoke in building

North Huron

Outcome: Overheated electrical equipment. No fire. FDNH ventilated the building and verified air quality.

31 March:

Possible fuel spill

North Huron

Outcome: Wind storm damaged building and vehicles resulting in damaged gasoline and diesel pumps.

